



2014002878Z



检测
CNAS L1020



(2014)国认监认字(347)号



实验室名称: 国家电器产品质量监督检验中心

Lab Name: China National Center for Quality Supervision
and Test of Electrical Apparatus Products

No 22M0024-S

检验 (试验) 报告

Test Report

委托单位: 华通机电股份有限公司

Client:

产品名称: 电力变压器

Name of Product:

产品型号: S11-M-500/10

Product Type:

检验类别: 委托试验

Test Category:

本实验室对出具的检验 (试验) 结果负责, 未经实验室书面同意, 不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.

国家电器产品质量监督检验中心

检 验 报 告

№: 22M0024-S

共 40 页 第 01 页

委托单位	华通机电股份有限公司	检验类别	委托试验
生产单位	华通机电股份有限公司	到样日期	2022年 01 月 30 日
产品名称	电力变压器	产品型号	S11-M-500/10
生产单位地址	浙江省乐清市经济开发区 纬七路203号	原编号或生产日期	202101181
检验日期	2022年 01 月 30 日至 2022年 02 月 11 日	送样数量	1 台
检验项目	例行试验 型式试验 三相变压器零序阻抗测量 短路承受能力试验	检验依据	GB1094.1—2013 GB1094.2—2013 GB1094.3—2003 GB1094.5—2008 GB/T1094.10—2003 GB/T6451—2008 JB/T10088—2004 委托书要求
检验结论	电力变压器（型号：S11-M-500/10）例行试验、型式试验、三相变压器零序阻抗测量、短路承受能力试验的试验结果符合检验依据标准和委托书要求，样品上述试验合格。  签发日期: 2022年 03 月 05 日 有效期五年		
备注	/		

批准: 朱品华 审定: 邵映琴 校核: 王永清 编制: 刘焯